

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0078:174 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: ADEMCO, 165 Eileen Way, Syosset NY 11791
Contact: *Harry Pashkoff (516) 921-6704 Fax (516) 364-6953

DESIGN: Models *FA1700C, Vista-100, Vista-128FB, *Vista-128FBP, *Vista-250FBP, and Vista-32FB fire alarm control units. Power-limited. Automatic, manual, noncoded, local, remote station, central station, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. Minimum system components:

Vista 100, Vista-128FB, -32FB	Control Unit
1451	Transformer
6137, 6137-R, 6139, 6139-R	Keypad

RATING: Primary 120 VAC, 18 VAC Secondary, 12 VDC Standby

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

- NOTE:**
1. For **Fire Alarm Verification Feature**, the maximum Retard/Reset/Restart period shall not exceed 30.0 seconds.
 2. Burglary and other non-fire functions were not examined.

*Rev. 11-25-2002KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **NOVEMBER 25, 2002**

Listing Expires **June 30, 2003**

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**